



## NOTES:

1. A 3 INCH METER SET REQUIRES A 4 INCH MINIMUM GATE VALVE AT THE MAIN AND A 4 INCH MINIMUM SUPPLY LINE.
2. 3 INCH METER SETS USE 1-1/2 INCH BYPASS. 4 INCH METER SETS USE 2 INCH BYPASS.
3. EXTEND TRACER WIRE A MINIMUM OF 48 INCHES INTO BOX.
4. PROVIDE CHRISTY N52 BOX WITH B52M3 LID. WHEN A LOCATION OUTSIDE OF PAVEMENT IS NOT POSSIBLE, PROVIDE AN H2O TRAFFIC RATED BOX WITH AN H2O TRAFFIC RATED READING LID.
5. STEEL PIPE SHALL BE PRIMED AND WRAPPED, MIN 10 MILS (CONFORMING TO SSPWC SECTION 203.07.04).
6. SWING CHECK VALVE AND ALL GATE VALVES (EXCEPT GATE VALVE AT MAIN) SHALL BE FLGxFLG. FCAs SHALL BE RESTRAINING TYPE, ROMAC OR APPROVED EQUAL. SEE DRAWING C-3.1.1.2, NOTE 21, FOR BOLTS, NUTS AND WASHERS MATERIAL REQUIREMENTS.
7. ALL FITTINGS OUTSIDE OF VALVE AT MAIN SHALL BE RESTRAINED.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	REM CHK VLV	9/17	<b>3"</b> AND <b>4"</b> <b>SERVICE &amp; METER SET</b>	CARSON CITY
2	STRAINER &	10/25		DRAWING NO. C-3.2.6
	SUPPORT			DATE OCT 2025
APPROVED BY: <u>DA</u>		10/25		