



TYPICAL SECTION

NTS

2) NOTES:

1. MUELLER 18 INCH LOCKING LID (MUELLER 780113) AND 27 INCH x 18 INCH FRAME (MUELLER 700098) OR APPROVED EQUAL.
2. MUELLER EZ-VAULT METER SETTER-RIGID PVC, FACTORY EQUIPPED AS SHOWN, CONFORMING TO AWWA C800, OR APPROVED EQUAL.
3. A 2 INCH METER SET REQUIRES A 2 INCH MINIMUM SERVICE LINE.
4. PIT SETTER EXTENSION, 6 INCH TOTAL MAXIMUM SHALL ONLY BE USED UPON APPROVAL BY CARSON CITY WATER UTILITY.
5. PIT SETTERS SHALL BE LOCATED OUTSIDE OF VEHICLE TRAFFIC AREAS, INCLUDING INCIDENTAL TRAFFIC AREAS, AND PARKING SHALL NOT BE ALLOWED OVER A PIT SETTER.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	NOTE 5	9/17		CARSON CITY
	INSUL PAD			DRAWING NO.
2	NOTES	10/25	1 1/2"-2" PIT SETTER	C-3.2.5
APPROVED BY:	<u>DA</u>	10/25		DATE
				OCT 2025