



### NOTES:

1. VALVE SHALL BE CUT IN A MINIMUM OF 40 FEET FROM NEW CONNECTION POINT UNLESS OTHERWISE APPROVED BY CITY WATER UTILITY MANAGER OR THEIR DESIGNEE.
2. CUT OPENING IN PIPE 1/2 INCH LONGER THAN TOTAL LENGTH OF VALVE, INSERT FLG x FLG VALVE USING FLANGED COUPLING ADAPTERS.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	NUT DEPTH	9/17	<b>CUT-IN GATE VALVE</b>	CARSON CITY
2	DEBRIS CAP	10/25		DRAWING NO. C-3.1.5
				DATE OCT 2025
APPROVED BY:	<u>DA</u>	10/25		