



RANKIN ENGINEERING

150 MANZANITA
CARSON CITY, NEVADA 89701
TELEPHONE (702) 882-3983



JIM RANKIN, P. E.

REG. - CAL. - NEV.

, 198

Carson City
Department of Community
Development
Walter Sullivan, Director
2621 Northgate Lane
Carson City, NV 89701


RE: Country Club Estates
Flood Zone "A.H." March 4, 1986
F.I.R.M. Map Panel 0080B

This is to Certify that I have Surveyed the construction of
a Mobile Home Residence on Lot 174 which is addressed
1179 DENISE CR Street.

I find the floor elevation to be 4642.4 ft.

By interpolation between the A.H. water surface elevations
shown on the F.I.R.M. map I find the 100 yr. flood water
surface elevation to be 4641.2 ft.

The floor elevation is therefore 1.2 ft. above
the 100 yr. flood.



James A. Rankin
N.R.E. and L.S. No. 1350