



TYPICAL SECTION

NTS

1

NOTES: 1

1. EXTEND TRACER WIRE AT LEAST 48" INTO METER BOX.
2. FORD A24-NL METER ADAPTER SHALL BE USED TO SET 5/8" X 3/4" METER.
3. METER BOXES SHALL BE LOCATED OUTSIDE OF VEHICLE TRAFFIC AREAS, EXCEPT FOR INCIDENTAL TRAFFIC AREAS, AND PARKING SHALL NOT BE ALLOWED OVER A METER SET UNLESS OTHERWISE APPROVED BY THE CITY ENGINEER OR THEIR DESIGNEE.
4. METER LIDS SHALL BE TIER 22 LOAD RATED UNLESS OTHERWISE APPROVED BY THE CITY ENGINEER OR THEIR DESIGNEE.
5. METER BOX AND LID SHALL BE SET 1" MINIMUM ABOVE FINISH GRADE, UNLESS SURROUNDED BY ASPHALT OR CONCRETE IN WHICH IT SHALL BE SET FLUSH WITH FINISH GRADE.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	TYP SECT &	10/25		CARSON CITY
	NOTES			DRAWING NO.
				C-3.2.3.1
				DATE
APPROVED BY: <u>DA</u>	10/25		1" SINGLE METER SET	OCT 2025