



ISOMETRIC VIEW

NTS

NOTES:

1. SERVICE LINES SHALL BE CTS C901 POLYETHYLENE TUBING (CONFORMING TO SSPWC 203.16.02) WITH TUBING LINERS AS PER FITTING MANUFACTURER'S INSTRUCTIONS.
2. SHORT BODY "Y" SHALL BE MUELLER CTS 110 COMP H-15343N, FORD QUICK JOINT Y44-274-Q-NL OR APPROVED EQUAL. CONNECT TO PE TUBING WITH TUBING LINER PER DRAWING C-3.2.1.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	BOX	10/25		CARSON CITY
				DRAWING NO.
				C-3.2.3.2
				DATE
APPROVED BY: <u>DA</u>	10/25		1" DUAL METER SET	OCT 2025