



1 TYPICAL SECTION
NTS

NOTES: 1

1. EXTEND TRACER WIRE AT LEAST 48" INTO METER BOX.
2. A 2 INCH METER SET REQUIRES A 2 INCH MINIMUM SERVICE LINE.
3. METER BOXES SHALL BE LOCATED OUTSIDE OF VEHICLE TRAFFIC AREAS, EXCEPT FOR INCIDENTAL TRAFFIC AREAS, AND PARKING SHALL NOT BE ALLOWED OVER A METER BOX, UNLESS OTHERWISE APPROVED BY THE CITY ENGINEER OR THEIR DESIGNEE.
4. METER BOX AND LID SHALL BE SET 1 INCH MINIMUM ABOVE FINISH GRADE, UNLESS SURROUNDED BY ASPHALT OR CONCRETE IN WHICH IT SHALL BE SET FLUSH WITH FINISH GRADE.
5. METER SETTER SHALL BE FORD COPPERSETTER VBHH76-18BHC-11-66-NL OR APPROVED EQUAL FOR A 1 1/2" METER, OR FORD COPPERSETTER VBHH77-18BHC-11-77-NL OR APPROVED EQUAL FOR A 2" METER.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	TYP SECT &	10/25		CARSON CITY
	NOTES			DRAWING NO.
				C-3.2.5.1
				DATE
APPROVED BY: <u>DA</u>	10/25		1 1/2"-2" METER SET	OCT 2025