



ISOMETRIC VIEW

NTS

NOTES:

- 1. SERVICE LINES SHALL BE CTS C901 POLYETHYLENE TUBING (CONFORMING TO SSPWC 203.16.02) WITH TUBING LINERS AS PER FITTING MANUFACTURER'S INSTRUCTIONS.
- 2. SHORT BODY "Y" SHALL BE MUELLER CTS 110 COMP H-15343N, FORD QUICK JOINT Y44-274-Q-NL OR APPROVED EQUAL. CONNECT TO PE TUBING WITH TUBING LINER PER DRAWING C-3.2.1.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	DETAIL NAME	3/22		CARSON CITY
2	NOTE 1	10/25		DRAWING NO. C-3.2.4
				DATE OCT 2025
APPROVED BY: <u>DA</u> 10/25			1"	DUAL PIT SETTERS