



TYPICAL SECTION

NTS

NOTES:

1. CONCRETE SHALL CONFORM TO THE SSPWC SECTION 202 AND 337.10. PORTLAND CEMENT CONCRETE (PCC) SHALL HAVE THE FOLLOWING CHARACTERISTICS: 4000 PSI MINIMUM COMPRESSIVE STRENGTH AT 28 DAYS, MINIMUM 6 SACKS OF CEMENT PER CUBIC YARD WITH A MAXIMUM WATER/CEMENT RATIO OF 0.45, AIR ENTRAINMENT $6\% \pm 1.5\%$, SLUMP AT 1 TO 4 INCHES. REBAR SHALL BE USED ONLY WHEN THE SEWER CLEANOUT IS LOCATED OUTSIDE PAVED AREAS.
2. LIDS SHALL BE SET FLUSH WITH FINISH GRADE UNLESS OTHERWISE NOTED.
3. WHEN LOCATED IN NDOT RIGHT-OF-WAY, CONCRETE COLLAR SHALL CONFORM TO NDOT STANDARD PLAN DS-49 AND STANDARD SPECIFICATION 609.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	REMOVE	3/22		CARSON CITY
	TRACER WIRE			DRAWING NO.
2	NOTE 1&3	4/25		C-2.2.3
APPROVED BY: <u>DA</u> 4/25				DATE APR 2025

SEWER CLEANOUT